

Exhaust emission data sheet C30 N6

60 Hz Spark ignited generator set EPA emissions

Engine information:			
Model:	QSJ2.4	Bore:	3.41 in. (86.5 mm)
Туре:	4 cycle, in-line, 4 cylinder	Stroke:	3.94 in. (100 mm)
Aspiration:	Naturally aspirated	Displacement:	146.46 cu. in. (2.4 liters)
Compression ratio:	9.5:1		
Emission control device:	Electronic air/fuel ratio control, and closed-loop breather system.		

	Natural gas	<u>Propane</u>
Performance data	<u>Standby</u>	<u>Standby</u>
BHP @ 1800 RPM (60 Hz)	49.5	49.5
Fuel consumption (SCFH)	380.9	164.1
Air to fuel ratio	16.6	14.7
Exhaust gas flow (CFM)	240.1	207.6
Exhaust gas temperature (°F)	1360	1400
Exhaust emission data		
HC (Total unburned hydrocarbons)*	53	458
NOx (Oxides of nitrogen as NO2)	1691	1573
CO (Carbon monoxide)	10663	19290
		Values are ppmvd
HC (Total unburned hydrocarbons)*	0.35	2.40
NOx (Oxides of nitrogen as NO2)	6.59	5.74
CO (Carbon monoxide)	29.80	50.35
		Values are Grams per HP-Hour

*HC includes all NMHC, VOC, POC, and ROC constituents (Non-Methane HC, Volatile Organic Compounds, Precursor Organic Compounds).

Test conditions

Data was recorded during steady-state rated engine speed (\pm 25 RPM) with full load (\pm 2%). Pressures, temperatures, and emission rates were stabilized.

Fuel specification:		
Natural gas	Dry gas as received from Supplier (1000 BTU/SCF).	
Propane	Meets the requirements for Commercial Grade Propane under the ASTM D1835 Standard Specification for Liquefied Gases	
Fuel temperature	60 ± 9 °F at Flow Transmitter	
Fuel pressure	14.73 PSIA \pm 0.5 PSIA at Flow Transmitter	
Intake air temperature:	77 ± 9 °F at inlet	
Barometric pressure:	29.92 in. Hg ± 1 in. Hg	
Humidity:	NOx measurement corrected to 75 grains H2O/lb dry air	

The NOx, HC, and CO emission data tabulated here were from a single engine under the test conditions shown above. These data are subjected to instrumentation and engine-to-engine variability. Field emission test data are not guaranteed to these levels. Actual field test results may vary due to test site conditions, installation, fuel specification, test procedures and instrumentation. Engine operation with excessive air intake or exhaust restriction beyond published maximum limit, or with improper maintenance, may results in elevated emission levels.